

Building	Room	Area	Height	Volume	CFM	CFHr	Air Changes	Actual CFM	Actual Air Changes
CLA	100	582.5	9	5243	800	48000	9	850	10
CLA	101	351.19	9	3161	380	22800	7	400	8
CLA	OFFICE 116	160	9	1440	330	19800	14	380	16
SFH	110	837	10	8370	1250	75000	9	1350	10
SFH	203	743	10	7430	940	56400	8	1100	9
SFH	OFFICE 319	181	9.5	1720	350	21000	12	400	14
Presser Hall	RECITAL 16A	540	10	5400	700	42000	8	750	8
Presser Hall	208	467	10	4670	810	48600	10	820	11
Presser Hall	OFFICE 110	463	10	4630	730	43800	9	1350	17
Presser Hall	OFFICE 109	471	10	4710	615	36900	8	900	11